

18 Attachment 1

Township of East Rockhill

Appendix “A”

1. Typical domestic levels for compatible pollutants shall be:

Parameter	Maximum Concentration (mg/l)
Biochemical Oxygen Demand (BOD5)	250(1)
Total Suspended Solids (TSS)	250(1)
Ammonia Nitrogen (NH ₃ -N)	25 as N(1)
Phosphorus (Total)	10 as P(1)
Total Kjeldahl Nitrogen (TKN)	40 as N(1)
Oil and Grease	100

2. In addition, no user shall contribute toxic pollutants to the Township’s sewer system in excess of the following:

Parameter	Maximum Concentration (mg/l)
Arsenic	0.04
Cadmium	0.04
Chromium, total	1.4
Chromium, hexavalent	0.7
Copper	0.75
Lead	0.07
Mercury	0.001
Molybdenum	0.09
Nickel	1.0
Selenium	0.3
Silver	0.1
Zinc	1.5
Total Phenols	1.0
Cyanide, total	0.34
Chloroform	0.2

SEWERS AND SEWAGE DISPOSAL

Parameter	Maximum Concentration (mg/l)
Bromo-Dichloromethane	0.05
Dibromo-chloromethane	0.07
PCBs	0.000002